Emission regimes of POPs of a Dutch incinerator: regulated, measured and hidden issues

Arkenbout, A, Olie K, Esbensen, KH



100th Anniversary of Regaining Independence by Poland



38th International Symposium on Halogenated Persistent Organic Pollutants

DioXin 2018

& 10th International PCB Workshop

26 - 31 August 2018, Kraków, Poland




TOXICO

'State of the art' incinerator, NL




Best Available Techniques (BAT): Furnace, ESP, Fabric Filter, SCR katalysator



A more stringent permit of 0,01 ng TEQ/Nm3 for dioxin emissions was given



Pollution of dioxins




ToxicoWatch research on eggs of backyard chicken shows contamination of dioxins in the environment of the incinerator



Dioxin emissions incinerator

Short-term

Regulated



- Long-term
- Optional, not in the Netherlands



- 12 hours measurement period (2 x 6 hours)
- Only under steady state conditions*
- Pre-announced

- Continuous sampling
- All conditions*

Adsorption MEthod for SAmpling of dioxins
AMESA

Sampling: 0,1 % of a year

uptime> 95 % a year



Short- vs long-term measurements


Sampling	hours	ng TEQ/Nm3	Factor
Short-term, March 30, 2016	6	<0,00001	
Long-term March 26– April 26, 2016	256	0,01290	>1290
Short-term, 8 March 2017	6	0,00001	
Long-term March 7 – April 5, 2017	690	0,00460	460

Sampling for official monitoring purposes must be *representative*. Short-term sampling *underestimating* emission dioxin levels.






Result longterm PCDD/F sampling






AMESA during failure



- uncontrolled burning of 19 ton undefined waste
- **3,5 hours** off during flushing of **dust** (50-100 kg) with bypassing filters
- Measured 0,17 ng/Nm3 when fire was off and the system was 'cleaned'.
- Emissions of dioxins was more the measured 27 mg PCDD/F (annual emission REC 5,3 mg)
- Factor 5



Use of bypasses



Commitment: stop use bypasses



Interruption of sampling

AMESA	Off-line	
Codes interrupting AMESA		
FA	No fire, Auxilairy burners off	
Alarm Power off	Failure by electricity or detonation	
O2 > O2OGR or < O2UGR	Oxygen under a certain value	
CO2 > CO2OGR or < CO2UGR	CO2 under a certain value	
TRG < TRGMIN:	Temperature flue gas < 70°	
VH <vhugr;< th=""><th>Velocity flue gas < 1,5 m/s</th></vhugr;<>	Velocity flue gas < 1,5 m/s	

These codes causes a stop of sampling in the AMESA cartridge After a leakage test of 3 minutes, sampling starts again

Total time off-line AMESA: 1496 hours (7,4%)





Shutdown/start-up data



REC 2 661:50 5:45 No fire Shutdown uncontrolled 2,6 REC 3 666:54 4:33 No fire Start-up 164,7 REC 10 256:17 6:26 VH < VHUGR, TRG < TRGMIN Shutdown 12,9 ODRA 7:43 408:00 Power off Maintenance, Start-up 1600 REC 15 640:55 5:49 VH < VHUGR Shutdown, Start-up 1,2 REC 16 646:12 4:53 VH < VHUGR Shutdown start-up 23,9 REC 17 119:38 0:41 VH < VHUGR Failure 16,7 REC 20 672:20 0:13 VH < VHUGR Shutdown start-up 1,2 REC 21 669:04 2:16 VH < VHUGR Shutdown 2,9 REC 22 433:10 0:55 VH < VHUGR Shutdown 4,6 ODRA 2:00 571:00 Manual command Maintenance, Start-up 1700 REC 28 408:50 0:17 VH < VHUGR Shutdown, Start-up 2,3 <th></th> <th>On-line</th> <th>Off-line AMESA</th> <th>Code AMESA</th> <th>Event</th> <th>pg TEQ /Nm³</th>		On-line	Off-line AMESA	Code AMESA	Event	pg TEQ /Nm³
REC 10 256:17 6:26 VH < VHUGR, TRG < TRGMIN 12,9	REC 2	661:50	5:45	No fire	Shutdown uncontrolled	2,6
Code	REC 3	666:54	4:33	No fire	Start-up	164,7
REC 15 640:55 5:49 VH < VHUGR Shutdown, Start-up, 1,2 REC 16 646:12 4:53 VH < VHUGR Shutdown Start-up, 23,9 REC 17 119:38 0:41 VH < VHUGR Failure 16,7 REC 20 672:20 0:13 VH < VHUGR Shutdown Start-up 1,2 REC 21 669:04 2:16 VH < VHUGR Shutdown 2,9 REC 22 433:10 0:55 VH < VHUGR Start-up 46,5 REC 26 578:03 0:10 VH < VHUGR Shutdown 4,6 ODRA 2:00 571:00 Manual command Maintenance, Start-up, 1700 REC 28 408:50 0:17 VH < VHUGR Shutdown, Start-up, 2,5 REC 30 665:22 3:38 VH < VHUGR Shutdown, Start-up, 2,5 REC 30 666:49 2:26 VH < VHUGR Shutdown, Start-up, 2,3 REC 32 666:49 2:26 VH < VHUGR Shutdown, Start-up, 2,3 REC 33 95:38 0:33 VH < VHUGR Shutdown, 0,3 REC 35 572:12 2:46 VH < VHUGR Shutdown 2,4 REC 36 124:35 32:30 TRG < TRGMIN Shutdown 10,4 REC 37 265:03 181:15 VH < VHUGR 69% off-line Start-up 11,3	REC 10	256:17	6:26		Shutdown	12,9
REC 16 646:12 4:53 VH < VHUGR Shutdown Start-up 23,9 REC 17 119:38 0:41 VH < VHUGR Failure 16,7 REC 20 672:20 0:13 VH < VHUGR Shutdown Start-up 1,2 REC 21 669:04 2:16 VH < VHUGR Shutdown 2,9 REC 22 433:10 0:55 VH < VHUGR Start-up 46,5 REC 25 578:03 0:10 VH < VHUGR Shutdown 4,6 ODRA 2:00 571:00 Manual command Maintenance, Start-up, 1700 REC 28 408:50 0:17 VH < VHUGR Shutdown, Start-up, 2,5 REC 30 665:22 3:38 VH < VHUGR Shutdown, Start-up, 2,3 REC 32 666:49 2:26 VH < VHUGR Shutdown, 0,3 REC 33 95:38 0:33 VH < VHUGR Shutdown, 0,3 REC 35 572:12 2:46 VH < VHUGR Shutdown 2,4 REC 36 124:35 32:30 TRG < TRGMIN Shutdown 10,4 REC 37 265:03 181:15 VH < VHUGR 69% off-line Start-up 11,3	ODRA	7:43	408:00	Power off	Maintenance, Start-up	1600
REC 17 119:38 O:41 VH < VHUGR Failure 16,7	REC 15	640:55	5:49	VH < VHUGR	Shutdown, Start-up,	1,2
REC 20 672:20 0:13 VH < VHUGR Shutdown 1,2	REC 16	646:12	4:53	VH < VHUGR	Shutdown Start-up	23,9
REC 21 669:04 2:16 VH < VHUGR	REC 17	119:38	0:41	VH < VHUGR	Failure	16,7
REC 22 433:10 0:55 VH < VHUGR	REC 20	672:20	0:13	VH < VHUGR	Shutdown Start-up	1,2
REC 26 578:03 0:10 VH < VHUGR Shutdown 4,6 ODRA 2:00 571:00 Manual command Maintenance, Start-up, 1700 REC 28 408:50 0:17 VH < VHUGR Shutdown, Start-up, 2,5 REC 30 665:22 3:38 VH < VHUGR Shutdown, Start-up 2,3 REC 32 666:49 2:26 VH < VHUGR Shutdown, 0,3 REC 33 95:38 0:33 VH < VHUGR Start-up 2,2 REC 35 572:12 2:46 VH < VHUGR Shutdown 2,4 REC 36 124:35 32:30 TRG < TRGMIN Shutdown 10,4 REC 37 265:03 181:15 VH < VHUGR 69% off-line Start-up 11,3	REC 21	669:04	2:16	VH < VHUGR	Shutdown	2,9
ODRA 2:00 571:00 Manual command Maintenance, Start-up, 1700 REC 28 408:50 0:17 VH < VHUGR	REC 22	433:10	0:55	VH < VHUGR	Start-up	46,5
REC 28 408:50 0:17 VH < VHUGR Shutdown, Start-up, 2,5 REC 30 665:22 3:38 VH < VHUGR	REC 26	578:03	0:10	VH < VHUGR	Shutdown	4,6
REC 30 665:22 3:38 VH < VHUGR Shutdown, Start-up 2,3 REC 32 666:49 2:26 VH < VHUGR Shutdown, 0,3 REC 33 95:38 0:33 VH < VHUGR Start-up 2,2 REC 35 572:12 2:46 VH < VHUGR shutdown 2,4 REC 36 124:35 32:30 TRG < TRGMIN shutdown 10,4 REC 37 265:03 181:15 VH < VHUGR 69% off-line Start-up 11,3	ODRA	2:00	571:00	Manual command	Maintenance, Start-up,	1700
REC 32 666:49 2:26 VH < VHUGR	REC 28	408:50	0:17	VH < VHUGR	Shutdown, Start-up,	2,5
REC 33 95:38 0:33 VH < VHUGR	REC 30	665:22	3:38	VH < VHUGR	Shutdown, Start-up	2,3
REC 35 572:12 2:46 VH < VHUGR shutdown 2,4 REC 36 124:35 32:30 TRG < TRGMIN shutdown 10,4 REC 37 265:03 181:15 VH < VHUGR 69% off-line Start-up 11,3	REC 32	666:49	2:26	VH < VHUGR	Shutdown,	0,3
REC 36 124:35 32:30 TRG < TRGMIN shutdown 10,4 REC 37 265:03 181:15 VH < VHUGR 69% off-line Start-up 11,3	REC 33	95:38	0:33	VH < VHUGR	Start-up	2,2
REC 37 265:03 181:15 VH < VHUGR 69% off-line Start-up 11,3	REC 35	572:12	2:46	VH < VHUGR	shutdown	
205.05 VH C VHOOK 69% OII-IIIIE Staft-up	REC 36	124:35	32:30	TRG < TRGMIN	shutdown	10,4
ELM 1:38 VH < VHUGR Maintenance, Start-up 563	REC 37	265:03	181:15	VH < VHUGR 69% off-line	Start-up	11,3
	ELM	1:38		VH < VHUGR	Maintenance, Start-up	563
TOTAL 1233:35	TOTAL		1233:35			

Maintenance-stop

Start up: "Electricity failure"

Maintenance-stop

Start up: "Miscommunication"

Maintenance-stop

Start up: "164 stops,

69 % AMESA offline"


Start-up: cold start-up Start-up: hot start-up,

When velocity comes under the level of 1,5 m/s, sampling stops.

When velocity comes above the level of 1,5 m/s, it takes 3 minutes to start sampling again Also when this happens within a minute



Start-ups and dust emissions



Parallel research by ODRA and EML, dust-data from REC






Excess emissions during start-ups

Phase 1	Pre-flushing
Phase 2	Flushing (cold)
Phase 3	Heating up
Phase 3B	Flushing (hot)
Phase 4	Starting waste feed
Phase 5	Regular operation

Parallel research by ODRA and EML (Not AMESA)








2018: NO improvement in dioxin reduction

Incinerator decides to stop the AMESA, despite it was already paid, the amendments of the government and the call from **the population to continue** the AMESA measurements



Start-up dust emissions




Most of the time, bypassing (dump stacks) takes only a few minutes



Night-shifts



Sample interruptions








Industrial cleaning

Explosion

REC problems with HCl and HF, Corrosion and dustclotting

SMART Explosion



Shock Pulse Generator

Media: Explosion with gas cylinder



What about interactions AMESA sampling?

persbericht ten, "Dit is

land d en de d 19 maa twee ci voerder soms vo val van e

> Online Boiler Cleaning with Controlled and Dosed Gas Explosions



Start-up after annual maintenance

AMESA


2016: Not performed because a local "electricity failure"/'explosion'

2017: Not performed because of "miscommunication"

2018: Performed only 31% because of sample break (VH < VHUGR).


AMESA only sampling after the dump-stacks of dust.

Data AMESA during start-ups are therefore incomplete, gravimetric measurements confirm this.





Hidden emissions



Hidden dioxin emissions

AMESA stops, but leaving many questions have arisen...



Conclusions

- Sampling must be representative, continuous sampling must be continuous, without interruptions
- Under no circumstances bypassing of flue gas/dust, even when there's no waste to burn
- Shutdown and start-ups should be included in dioxin emissions calculation/regulation
- Start-ups cause exceeding dioxin emissions
- More research on industrial cleaning (detonation), maybe science is a step behind
- AMESA is a step ahead in sampling, but still there're a lot of shortcomings
- "Economy first" should not be No 1 on behalf of our health and our environment

See also posters ToxicoWatch UPOP emissions and Postcombustion temperatures



Acknowledgement

Contributions on our ToxicoWatch research

- S.A. Environnement; *AMESA*, *Hamburg*, *Germany*
- BDS, BioDetection System, Amsterdam, CALUX eggs
- GGD, Public Health Service,
- ODRA, Omgevingsdienst Regio Arnhem, shortterm measurements
- Arcadis, Consultancy
- Witteveen en Bosch, Consultancy
- MOBilisation for the Environment, Consultancy
- Sarolea lawyers
- KH Consultancy, *University Aalborg, Denmark*
- Local council township Harlingen,
- Governement Province Fryslan,
- REC, Reststoffen Energie Centrale, incinerator Harlingen
- IBED/ESPM, University of Amsterdam



Thank you for your attention

Special thanks to all the people who support the work of NGO ToxicoWatch in order to make the world a little bit more sustainable